



CITY OF VIRGINIA BEACH FIRE DEPARTMENT
FIRE INSPECTION REPORT
FIRE MARSHAL'S OFFICE
Office 385-4228 Fax 385-5676

New Business
Name Change
Permit Required
Page ___ of ___

Occupancy SMOKIE'S BART GRILL VBFD# 815 Class Code A-2
Address 1715 HARPER RD Suite _____ Zip _____
To: JOHN PAPAKOSTAS Phone # [REDACTED]

(owner, occupancy, manager or responsible person(s))

Type of Inspection Routine Complaint Re-inspection # _____

Code Violation(s) Request _____

Fire Code Section	Time In: 0945	Time Out: 1025	Remarks
505.1			New & existing bldg's required to have address posted
904.5			WET chemical systems required to be tested / inspected every 6 mos. last completed 1/11
605.1			Electrical hazards prohibited. a) Backroom: electrical panel missing internal cover plate. b) Back room: install cover on receptical c) FRZRN area: Timer box: install cover
1004.3			Posting of occupancy load required for A-2 shd
906.2			Class-K extinguisher due for 5yr hydro hydrostatic pressure test.

Occupant _____ Date _____

Inspector _____ Insp. # _____

NOTICE OF VIOLATION

The items noted above are in violation of the Virginia Statewide Fire Prevention Code and Section 12-51 of the Code of the City of Virginia Beach, Virginia. This is an official notice of ordinance violation requiring immediate correction. Failure to comply with these requirements may lead to legal action. Violation of the Fire Prevention Code is a Class 1 Misdemeanor punishable by a fine not to exceed Twenty-Five Hundred Dollars or imprisonment not exceeding 12 months or both. For information concerning this inspection call the Fire Marshal's Office.

Note: There will be a \$25 re-inspection fee for the third re-inspection and every subsequent inspection.

Re-inspection will be done on or after 7 Days

Occupant [Signature]

Inspector Keith D. Crow Insp. # 75 Date 1/18/11 Time 1025



CITY OF VIRGINIA BEACH FIRE DEPARTMENT
FIRE INSPECTION REPORT
FIRE MARSHAL'S OFFICE
Office 385-4228 Fax 385-5676

New Business
Name Change
Permit Required
Page 1 of 1

Occupancy Smokies Sports Bar VBFD# _____ Class Code A-2
Address 1715 Harpers Road Suite --- Zip 23456
To: X John Papakostas Phone # 422-5773
(owner, occupancy, manager or responsible person(s))

Type of Inspection Routine Complaint Request
Code Violation(s) _____ Re-inspection # 1

Fire Code Section	Time In:	Remarks	Time Out:
	<u>1000</u>		<u>1200</u>
		<u>Business has had occupant load reduced to (49) people. This is a temporary occupant load put in place do to fire and building code violations. The occupant load will stay at (49) until repairs are made.</u>	
		<u>- Owner of business shall install panic hardware on front door</u>	
		<u>- Owner has agreed to not use the back rooms do to egress issues. Do to the door opening in the room wrong direction of travel.</u>	
		<u>Temp Occ. load (49)</u>	

Occupant _____ Date _____
Inspector _____ Insp. # _____

NOTICE OF VIOLATION

The items noted above are in violation of the Virginia Statewide Fire Prevention Code and Section 12-4 of the Code of the City of Virginia Beach, Virginia. This is an official notice of ordinance violation requiring immediate correction. Failure to comply with these requirements may lead to legal action. Violation of the Fire Prevention Code is a Class 1 Misdemeanor punishable by a fine not to exceed Twenty-Five Hundred Dollars or imprisonment not exceeding 12 months or both. For information concerning this inspection call the Fire Marshal's Office.

Note: All re-inspection(s) beyond the third re-inspection will incur a fee of \$25.00

Re-inspection will be done on or after owner will call
Occupant [Signature]
Inspector Sweeney Insp. # 4 Date Dec 5 Time 1142